

Letter No. PHC/JTS/2023/245

Dated:- 14/06/2023

Sanitation certificate

It is certified that premises of B. P. school Rojhuwas, District Rewari was inspected by the Authority Health Department Rewari P.H.C Jatusana. As per report of inspection the sanitation and hygienic conditions of the school is satisfactory.

Medical officer/ Incharge,

P.H.C Jatusana.

Medical officer (I/c)
PHC Jatusana (Rev)


संचय
भारतीय शिक्षा समिति रोहड़ा,
(रेवाड़ी)

Nirmala Kumari
Principal
B. P. Sr. Sec. School
Rojhuwas, Rewari (Hr.)

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, REWARI

Website :- <https://phedharyana.gov.in/>

Memo No:- 743

Date:- 13/06/2023

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	REW/00644/6/2023	Sample Details	Date & Time
Sample Classification:	Private	Collected By	,9896901449
Sender:	PRINCIPAL BP SCHOOL ROJHUWAS22078	Collection Date	09/06/2023 at 14:39
Location :-	, VILL ROJHUWAS, P.O. ROHRAI DISTT REWARI	Received at lab	09/06/2023 at 15:22
Latitude :-	76.583022	Tested at Lab	12/06/2023
Longitude :-	28.316863		

Test Result (As Per BIS 10500 :2012)

S.No,	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in REWARI lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters, the water sample is found "**POTABLE**"




KANTA PUNIA, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, REWARI
email:-chemist.rewari@phedharyana.gov.in

-----End of Report-----


संचालक
भारतीय शिक्षा समिति रोहड़ा,
(रेवाड़ी)

Nirmala Kumari
Principal
B. P. Sr. Sec. School
Rojhuwas, Rewari (Hr.)